

TRANSFER TANK INSPECTION
(Less than 119 gallons capacity in pickup/utility trucks etc.)

REGISTRATION # _____ VIN# _____

	YES	NO
Tank is minimum 14 gauge steel or 1/8 inch aluminum	_____	_____
Tank is securely mounted to bed or body of the vehicle	_____	_____
Suitable pump with durable hose & self closing nozzle	_____	_____
Fire extinguisher minimum 1A, 10B, C rating	_____	_____
Vehicle contains a hoist to raise bed or body (prohibited)	_____	_____

PLACARDS ARE NOT REQUIRED

INSPECTED BY: _____

Date _____ Permit# _____