

TRANSFER TANK INSPECTION
(less than 119 gallons capacity in pickup/utility trucks, etc.)

REGISTRATION # _____ VIN # _____

	Yes	No
Tank is minimum 14 gauge steel or 1/8 inch aluminum	_____	_____
Tank is securely mounted to bed or body of vehicle	_____	_____
Suitable pump with durable hose and self-closing nozzle	_____	_____
Fire extinguisher minimum 1A, 10B, C rating	_____	_____
Vehicle contains a hoist to raise bed or body (Prohibited)	_____	_____

PLACARDS ARE NOT REQUIRED

Inspected by: _____

Fire Department: _____

Permit # _____ Date: _____